

Fire Protection Survey Services TM

P.O. Box 170
Longford Mills, Ontario, Canada, L0K 1L0
Telephone: (705) 689-6183 Fax: (208) 474-3520
E-mail: firepss@bell.net Website: www.fpss.ca

Fire Department Water Tanker Shuttle Accreditation

Presented To: Tyendinaga Mohawk Territory

ACCREDITED FIRE STATIONS

Tyendinaga Mohawk F.S. (Basic Tanker Shuttle)

(*)=Commercial / Industrial Fire Protection Classification – N/A

Date Test Passed: September 23, 2014

Flow Achieved: 235 I.G.P.M. 1065 LITERS/MIN.

Two (2) Hour Test Time



Signed: Peter J. Rose ~

Peter J. Rose, C.E.T., F.P.T.
Senior Partner
Senior Fire Protection Specialist
Senior Loss Control Specialist

This Certificate Expires on October 01, 2019

FPSS "Professionalism With Pride"®