



Not Reportable as per Chain of Custody Works #: 1156

Project : PO#017018

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2HO
Phone: 705-652-2000 FAX: 705-652-6365

12-February-2015

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 10 February 2015
LR Report: CA17732-FEB15

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Temperature Time Upon Receipt °C	Field Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli Heterotrophic cfu/100mL	Plate Count (HPC) cfu/1mL
1: Analysis Start Date	---	---	10-Feb-15	10-Feb-15	10-Feb-15
2: Analysis Start Time	---	---	16:50	16:50	16:25
3: Analysis Approval Date	--	--	12-Feb-15	12-Feb-15	12-Feb-15
4: Analysis Approval Time	--	--	09:36	09:36	14:08
5: MAC	--	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	09-Feb-15 08:22	6.0	12	0	7
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	09-Feb-15 08:42	6.0	1.52	0	0
8: 1F432 NR/DW DW3-QMS: Fountain Water Front Entrance 1F432 NR/DW	09-Feb-15 08:35	6.0	1.17	0	1

Method Descriptions

	Parameter	Description	SGS Method Code
1	E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
2	Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
3	Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001


 Carrie Greenlaw
 Project Specialist
 Environmental Services, Analytical