

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - KOL 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

06-November-2014

**OCWA-Trent Valley (Quinte Mohawk School)**

Attn : James Taylor

Date Rec. : 04 November 2014  
LR Report: CA16053-NOV14

Box 20157, 131 St. Paul St.  
Belleville, ON  
K8N 5V1,

Copy: #1

Phone: 613-962-5454  
Fax:pdf-ID Plant

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Total Chlorine mg/L	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	04-Nov-14	04-Nov-14	04-Nov-14
2: Analysis Start Time		---	---	---	12:00	12:00	11:35
3: Analysis Approval Date		--	---	--	06-Nov-14	06-Nov-14	06-Nov-14
4: Analysis Approval Time		--	---	--	10:29	10:29	10:29
5: MAC		--	---	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	03-Nov-14 08:45		14.0	---	0	0	4
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	03-Nov-14 08:35		14.0	1.16	1.14	0	0
8: 13481 NR/DW DW3-QMS: Fountain Water Boys Bathroom 13481 NR/DW	03-Nov-14 08:25		14.0	1.05	0.92	0	20

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.

#### Method Descriptions

	Parameter	Unit	Description	SGS Method Code
1	E. Coli	cfu/100mL	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
2	Heterotrophic Plate Count (HPC)	cfu/1mL	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
3	Total Coliform	cfu/100mL	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

Carrie Greenlaw  
 Project Specialist  
 Environmental Services, Analytical