



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Not Reportable as per Chain of Custody  
Works #: 1156**

**Project : PO#017018**

04-December-2014

**OCWA-Trent Valley (Quinte Mohawk School)**

Attn : James Taylor

**Date Rec. : 02 December 2014  
LR Report: CA16057-DEC14**

Box 20157, 131 St. Paul St.  
Belleville, ON  
K8N 5V1,

**Copy: #1**

Phone: 613-962-5454  
Fax: pdf-ID Plant

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Total Chlorine mg/L	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	02-Dec-14	02-Dec-14	02-Dec-14
2: Analysis Start Time		---	---	---	14:00	14:00	13:30
3: Analysis Approval Date		--	---	--	03-Dec-14	03-Dec-14	04-Dec-14
4: Analysis Approval Time		--	---	--	16:16	16:16	11:00
5: MAC		--	---	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	01-Dec-14 08:30	9.0	---	---	0	0	15
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	01-Dec-14 08:25	9.0	1.39	1.21	0	0	0
8: 1EC6A NR DW DW2-QMS Staff Room Tap 1EC6A NR/DW	01-Dec-14 08:15	9.0	1.25	1.07	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.

### Method Descriptions

	Parameter	Description	SGS Method Code
1	E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
2	Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
3	Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

  
 Carrie Greenlaw  
 Project Specialist  
 Environmental Services, Analytical