



SGS Canada Inc.
P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 1156
Project : PO#017018

15-January-2014

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 07 January 2014
LR Report: CA16100-JAN14

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Analysis	1: Analysis Start Date	2: Analysis Start Time	3: Analysis Approval Date	4: Analysis Approval Time	5: MAC	6: Half MAC	7: AO/OG	8: MDL	9: TW TW-NR/TW Treated Water Tap
Sample Date & Time									06-Jan-14 09:55
Temperature Upon Receipt [°C]	---	---	--	--	--	--	---	---	4.0
Free Chlorine [mg/L]	---	---	--	--	--	--	---	---	1.59
Antimony [ug/L]	08-Jan-14	12:01	08-Jan-14	14:14	6	3	---	0.02	0.02 <MDL
Arsenic [ug/L]	08-Jan-14	12:01	08-Jan-14	14:14	25	12.5	---	0.2	0.4
Barium [ug/L]	08-Jan-14	12:01	08-Jan-14	14:14	1000	500	---	0.01	91.6
Boron [ug/L]	08-Jan-14	12:01	08-Jan-14	14:14	5000	2500	---	0.2	118
Cadmium [ug/L]	08-Jan-14	12:01	08-Jan-14	14:14	5	2.5	---	0.003	0.003 <MDL
Chromium [ug/L]	08-Jan-14	12:01	08-Jan-14	14:14	50	25	---	0.5	0.8
Mercury [ug/L]	08-Jan-14	14:07	08-Jan-14	14:18	1	0.5	---	0.01	0.01 <MDL
Selenium [ug/L]	08-Jan-14	12:01	08-Jan-14	14:13	10	5	---	1	1
Uranium [ug/L]	08-Jan-14	12:01	08-Jan-14	14:13	20	10	---	0.001	2.67
Benzene [ug/L]	08-Jan-14	15:47	09-Jan-14	11:01	5	2.5	---	0.32	0.32 <MDL
Carbon tetrachloride [ug/L]	08-Jan-14	15:47	09-Jan-14	11:01	5	2.5	---	0.16	0.16 <MDL
1,2-Dichlorobenzene [ug/L]	08-Jan-14	15:47	09-Jan-14	11:01	200	100	3	0.41	0.41 <MDL
1,4-Dichlorobenzene [ug/L]	08-Jan-14	15:47	09-Jan-14	11:01	5	2.5	1	0.36	0.36 <MDL
1,1-Dichloroethylene (vinylidene chloride) [ug/L]	08-Jan-14	15:47	09-Jan-14	11:01	14	7	---	0.33	0.33 <MDL
1,2-Dichloroethane [ug/L]	08-Jan-14	15:47	09-Jan-14	11:01	5	2.5	---	0.35	0.35 <MDL
Dichloromethane [ug/L]	08-Jan-14	15:47	09-Jan-14	11:01	50	25	---	0.35	0.35 <MDL
Monochlorobenzene [ug/L]	08-Jan-14	15:47	09-Jan-14	11:01	80	40	30	0.30	0.3 <MDL
Tetrachloroethylene (perchloroethylene) [ug/L]	08-Jan-14	15:47	09-Jan-14	11:01	30	15	---	0.35	0.35 <MDL
Trichloroethylene [ug/L]	08-Jan-14	15:47	09-Jan-14	11:01	5	2.5	---	0.44	0.44 <MDL
Vinyl Chloride [ug/L]	08-Jan-14	15:47	09-Jan-14	11:01	2	1	---	0.17	0.17 <MDL
Diquat [ug/L]	09-Jan-14	09:18	14-Jan-14	17:18	70	35	---	1	1 <MDL
Paraquat [ug/L]	09-Jan-14	09:18	14-Jan-14	17:18	10	5	---	1	1 <MDL
Glyphosate [ug/L]	09-Jan-14	08:35	10-Jan-14	13:56	280	140	---	1	1 <MDL
Polychlorinated Biphenyls (PCBs) - Total [ug/L]	07-Jan-14	14:53	09-Jan-14	11:22	3	1.5	---	0.04	0.04 <MDL
Benzo(a)pyrene [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	0.01	0.005	---	0.004	0.004 <MDL
Alachlor [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	5	2.5	---	0.02	0.02 <MDL
Aldicarb [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	9	4.5	---	0.01	0.01 <MDL
Aldrin + Dieldrin [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	0.7	0.35	---	0.01	0.01 <MDL
Aldrin [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	--	--	---	0.01	0.01 <MDL
Dieldrin [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	--	--	---	0.01	0.01 <MDL
Atrazine + N-dealkylated metabolites [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	5	2.5	---	0.01	0.01 <MDL
Atrazine [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	--	--	---	0.01	0.01 <MDL
Desethyl atrazine [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	--	--	---	0.01	0.01 <MDL
Azinphos-methyl [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	20	10	---	0.02	0.02 <MDL

Online LIMS

0000092428



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 1156

Project : PO#017018

LR Report : CA16100-JAN14

Analysis	1: Analysis Start Date	2: Analysis Start Time	3: Analysis Approval Date	4: Analysis Approval Time	5: MAC	6: Half MAC	7: AO/OG	8: MDL	9: TW TW-NR/TW Treated Water Tap
Bendiocarb [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	40	20	---	0.01	0.01 <MDL
Carbaryl [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	90	45	---	0.01	0.01 <MDL
Carbofuran [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	90	45	---	0.01	0.01 <MDL
Chlordane (total) [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	7	3.5	---	0.01	0.01 <MDL
a-chlordane [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	--	--	---	0.01	0.01 <MDL
g-chlordane [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	--	--	---	0.01	0.01 <MDL
Oxychlordane [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	--	--	---	0.01	0.01 <MDL
Chlorpyrifos [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	90	45	---	0.02	0.02 <MDL
Cyanazine [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	10	5	---	0.03	0.03 <MDL
Diazinon [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	20	10	---	0.02	0.02 <MDL
(DDT) + Metabolites [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	30	15	---	0.01	0.01 <MDL
op-DDT [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	--	--	---	0.01	0.01 <MDL
pp-DDD [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	--	--	---	0.01	0.01 <MDL
pp-DDE [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	--	--	---	0.01	0.01 <MDL
pp-DDT [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	--	--	---	0.01	0.01 <MDL
Dimethoate [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	20	10	---	0.03	0.03 <MDL
Diuron [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	150	75	---	0.03	0.03 <MDL
Heptachlor + Heptachlor Epoxide [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	3	1.5	---	0.01	0.01 <MDL
Heptachlor [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	--	--	---	0.01	0.01 <MDL
Heptachlor epoxide [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	--	--	---	0.01	0.01 <MDL
Lindane [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	4	2	---	0.01	0.01 <MDL
Malathion [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	190	95	---	0.02	0.02 <MDL
Methoxychlor [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	900	450	---	0.01	0.01 <MDL
Metolachlor [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	50	25	---	0.01	0.01 <MDL
Metribuzin [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	80	40	---	0.02	0.02 <MDL
Parathion [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	50	25	---	0.02	0.02 <MDL
Phorate [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	2	1	---	0.01	0.01 <MDL
Prometryne [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	1	0.5	---	0.03	0.03 <MDL
Simazine [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	10	5	---	0.01	0.01 <MDL
Temephos [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	280	140	---	0.01	0.01 <MDL
Terbufos [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	1	0.5	---	0.01	0.01 <MDL
Triallate [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	230	115	---	0.01	0.01 <MDL
Trifluralin [ug/L]	08-Jan-14	07:51	09-Jan-14	12:26	45	22.5	---	0.02	0.02 <MDL
2,4-dichlorophenoxyacetic acid (2,4-D) [ug/L]	08-Jan-14	08:29	13-Jan-14	09:11	100	50	---	0.19	0.19 <MDL
2,4,5-trichlorophenoxyacetic acid (2,4,5-T) [ug/L]	08-Jan-14	08:29	13-Jan-14	09:11	280	140	20	0.22	0.22 <MDL
Bromoxynil [ug/L]	08-Jan-14	08:29	13-Jan-14	09:11	5	2.5	---	0.33	0.33 <MDL
Dicamba [ug/L]	08-Jan-14	08:29	13-Jan-14	09:11	120	60	---	0.2	0.20 <MDL
Diclofop-methyl [ug/L]	08-Jan-14	08:29	13-Jan-14	09:11	9	4.5	---	0.4	0.40 <MDL
Dinoseb [ug/L]	08-Jan-14	08:29	13-Jan-14	09:11	10	5	---	0.36	0.36 <MDL
Picloram [ug/L]	08-Jan-14	08:29	13-Jan-14	09:11	190	95	---	1	1 <MDL
2,4-dichlorophenol [ug/L]	08-Jan-14	08:29	13-Jan-14	09:11	900	450	0.3	0.15	0.15 <MDL
2,4,6-trichlorophenol [ug/L]	08-Jan-14	08:29	13-Jan-14	09:11	5	2.5	2	0.25	0.25 <MDL
2,3,4,6-tetrachlorophenol [ug/L]	08-Jan-14	08:29	13-Jan-14	09:11	100	50	1	0.14	0.14 <MDL
Pentachlorophenol [ug/L]	08-Jan-14	08:29	13-Jan-14	09:11	60	30	30	0.15	0.15 <MDL

SGS Canada Inc.


P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Works #: 1156

Project : PO#017018

LR Report : CA16100-JAN14

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.
MAC - Maximum Acceptable Concentration
Half MAC - Half of the Maximum Acceptable Concentration
AO/OG - Aesthetic Objective / Operational Guideline
MDL - SGS Method Detection Limit



Carrie Greenlaw
Project Specialist
Environmental Services, Analytical