

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - KOL 2HO  
Phone: 705-652-2000 FAX: 705-652-6365

19-March-2015

**OCWA-Trent Valley (Quinte Mohawk School)**

Attn : James Taylor

Date Rec. : 17 March 2015  
LR Report: CA16449-MAR15

Box 20157, 131 St. Paul St.  
Belleville, ON  
K8N 5V1,

Copy: #1

Phone: 613-962-5454  
Fax:pdf-ID Plant

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	17-Mar-15	17-Mar-15	17-Mar-15
2: Analysis Start Time		---	---	16:45	16:45	16:25
3: Analysis Approval Date		--	--	18-Mar-15	18-Mar-15	19-Mar-15
4: Analysis Approval Time		--	--	15:45	15:45	14:31
5: MAC		--	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	16-Mar-15 08:50	7.0	---	12	0	202
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	16-Mar-15 09:00	7.0	1.78	0	0	0
8: 1EC6A NR DW DW2-QMS Staff Room Tap 1EC6A NR/DW	16-Mar-15 08:56	7.0	1.53	0	0	0

### Method Descriptions

	Parameter	Description	SGS Method Code
1	E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
2	Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
3	Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

  
 Carrie Greenlaw  
 Project Specialist  
 Environmental Services, Analytical