



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

18-December-2014

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 16 December 2014
LR Report: CA16484-DEC14

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field Total Chlorine mg/L	Field Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	16-Dec-14	16-Dec-14	16-Dec-14
2: Analysis Start Time		---	---	---	13:15	13:15	12:45
3: Analysis Approval Date		--	---	--	17-Dec-14	17-Dec-14	18-Dec-14
4: Analysis Approval Time		--	---	--	17:22	17:22	11:08
5: MAC		--	---	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	15-Dec-14 08:25	9.0	---	---	0	0	8
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	15-Dec-14 08:15	9.0	1.96	1.68	0	0	0
8: 1F432 NR/DW DW3-QMS: Front Entrance Fountain 1F432 NR/DW	15-Dec-14 08:05	9.0	0.98	0.85	0	0	3

Method Descriptions

	Parameter	Description	SGS Method Code
1	E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
2	Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
3	Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001


 Carrie Greenlaw
 Project Specialist
 Environmental Services, Analytical