



Not Reportable as per Chain of Custody Works #: 1156

Project : PO#017018

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

02-October-2014

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 30 September 2014
LR Report: CA16634-SEP14

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Total Chlorine mg/L	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	30-Sep-14	30-Sep-14	30-Sep-14
2: Analysis Start Time		---	---	---	11:15	11:15	10:55
3: Analysis Approval Date		--	---	--	01-Oct-14	01-Oct-14	02-Oct-14
4: Analysis Approval Time		--	---	--	13:53	13:53	11:13
5: MAC		--	---	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	29-Sep-14 08:25	18.0	---	---	0	0	10
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW1	29-Sep-14 08:15	18.0	1.58	1.40	0	0	0
8: 13480 NR/DW DW3-QMS: Girls Washroom Fountain 13480 NR/DW3	29-Sep-14 08:05	18.0	1.49	1.31	0	0	4

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.

Method Descriptions

	Parameter	Unit	Description	SGS Method Code
1	E. Coli	cfu/100mL	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
2	Heterotrophic Plate Count (HPC)	cfu/1mL	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
3	Total Coliform	cfu/100mL	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001


 Carrie Greenlaw
 Project Specialist
 Environmental Services, Analytical