

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St. Lakefield - Ontario - KOL 2HO

Phone: 705-652-2000 FAX: 705-652-6365

Not Reportable as per Chain of Custody

Works #: 1156

Project: PO#017018

19-December-2013

Date Rec.: 17 December 2013 LR Report: CA16818-DEC13

Copy: #1

OCWA-Trent Valley (Quinte Mohawk School)

Attn: James Taylor

Box 20157, 131 St. Paul St. Belleville, ON K8N 5V1,

Phone: 613-962-5454 Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date				17-Dec-13	17-Dec-13	17-Dec-13
2: Analysis Start Time				15:50	15:50	15:25
3: Analysis Approval Date				18-Dec-13	18-Dec-13	19-Dec-13
4: Analysis Approval Time				17:32	17:32	14:59
5: MAC				0	0	
6: 26F9D RW-QMS: Raw Water 26F9D RW	16-Dec-13 10:00	4.0		0	0	88
7: 6712 DW1-QMS Daycare 6712 NR/DW	16-Dec-13 10:17	4.0	1.18	0	0	1
8: 1EC6A DW2-QMS Staff Room Tap 1EC6A NR/DW	16-Dec-13 10:25	4.0	1.25	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.

Project Specialist

Environmental Services, Analytical