

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

29-December-2014

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 23 December 2014
LR Report: CA16819-DEC14

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Field Total Chlorine mg/L	Field Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	23-Dec-14	23-Dec-14	23-Dec-14
2: Analysis Start Time		---	---	---	14:45	14:45	14:05
3: Analysis Approval Date		--	---	--	24-Dec-14	24-Dec-14	29-Dec-14
4: Analysis Approval Time		--	---	--	12:58	12:58	09:41
5: MAC		--	---	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	22-Dec-14 08:20	11.0	---	---	0	0	11
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	22-Dec-14 08:10	11.0	1.67	1.40	0	0	1
8: 1F432 NR/DW DW3-QMS: Fountain Water Front Entrance 1F432 NR/DW	22-Dec-14 08:00	11.0	1.02	0.85	0	0	1

Method Descriptions

	Parameter	Description	SGS Method Code
1	E. Coli	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
2	Heterotrophic Plate Count (HPC)	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
3	Total Coliform	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001


 Carrie Greenlaw
 Project Specialist
 Environmental Services, Analytical