

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - KOL 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

30-October-2014

**OCWA-Trent Valley (Quinte Mohawk School)**

Attn : James Taylor

Date Rec. : 28 October 2014

LR Report: CA16924-OCT14

Box 20157, 131 St. Paul St.  
Belleville, ON  
K8N 5V1,

Copy: #1

Phone: 613-962-5454  
Fax:pdf-ID Plant

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Total Chlorine mg/L	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	28-Oct-14	28-Oct-14	28-Oct-14
2: Analysis Start Time		---	---	---	15:40	15:40	15:05
3: Analysis Approval Date		--	---	--	30-Oct-14	30-Oct-14	30-Oct-14
4: Analysis Approval Time		--	---	--	09:43	09:43	13:28
5: MAC		--	---	--	0	0	---
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	27-Oct-14 08:00	13.0	---	---	0	0	3
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	27-Oct-14 08:20	13.0	0.46	0.40	0	0	2
8: 13480 NR/DW DW3-QMS: Fountain Water Girls Bathroom 13480 NR/DW	27-Oct-14 08:10	13.0	0.71	0.53	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.

#### Method Descriptions

	Parameter	Unit	Description	SGS Method Code
1	E. Coli	cfu/100mL	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
2	Heterotrophic Plate Count (HPC)	cfu/1mL	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
3	Total Coliform	cfu/100mL	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001

  
 Carrie Greenlaw  
 Project Specialist  
 Environmental Services, Analytical