

**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - KOL 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

26-September-2013

**OCWA-Trent Valley (Quinte Mohawk School)**

Attn : James Taylor

Date Rec. : 24 September 2013  
LR Report: CA16929-SEP13

Box 20157, 131 St. Paul St.  
Belleville, ON  
K8N 5V1,

Copy: #1

Phone: 613-962-5454  
Fax:pdf-ID Plant

## CERTIFICATE OF ANALYSIS

### Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	24-Sep-13	24-Sep-13	24-Sep-13
2: Analysis Start Time		---	---	15:40	15:40	14:55
3: Analysis Approval Date		--	--	26-Sep-13	26-Sep-13	26-Sep-13
4: Analysis Approval Time		--	--	13:11	13:11	13:11
5: MAC		--	--	0	0	---
6: 26F9D RW RW QMS: Raw Water	23-Sep-13 12:58	10.0	---	0	0	22
7: 6712 NR/DW DW1 QMS Daycare	23-Sep-13 13:20	10.0	0.81	0	0	0
8: 1EC6A NR/DW DW2 QMS Staff Room Tap	23-Sep-13 13:11	10.0	1.11	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.



Carrie Greenlaw  
Project Specialist  
Environmental Services, Analytical