



Not Reportable as per Chain of Custody Works #: 1156

Project : PO#017018

SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2H0
Phone: 705-652-2000 FAX: 705-652-6365

21-October-2014

OCWA-Trent Valley (Quinte Mohawk School)

Attn : James Taylor

Date Rec. : 15 July 2014
LR Report: CA17032-JUL14

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Total Chlorine mg/L	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	---	15-Jul-14	15-Jul-14	15-Jul-14
2: Analysis Start Time		---	---	---	18:05	18:05	17:40
3: Analysis Approval Date		--	---	--	17-Jul-14	17-Jul-14	18-Jul-14
4: Analysis Approval Time		--	---	--	14:15	14:15	09:50
5: MAC		--	---	--	0	0	---
6: RW RW-QMS: Raw Water 26F9D RW	14-Jul-14 08:10	21.0	---	---	0	0	5
7: DW DW1-QMS Daycare 6712 NR/DW	14-Jul-14 08:40	21.0	0.98	0.77	0	0	19
8: DW DW2-QMS Staff Room Tap 1EC6A NR/DW	14-Jul-14 08:30	21.0	1.43	1.27	0	0	5

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.

Method Descriptions

	Parameter	Unit	Description	SGS Method Code
1	E. Coli	cfu/100mL	E.Coli by membrane filtration on DC media	ME-CA-[ENV]MIC-LAK-AN-001
2	Heterotrophic Plate Count (HPC)	cfu/1mL	Heterotrophic Plate Count by membrane filtration	ME-CA-[ENV]MIC-LAK-AN-005
3	Total Coliform	cfu/100mL	Total Coliform by membrane filtration using DC media	ME-CA-[ENV]MIC-LAK-AN-001


 Carrie Greenlaw
 Project Specialist
 Environmental Services, Analytical