



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Project :** PO#017018

January-17-13

**OCWA-Trent Valley (Quinte Mohawk School)**

Attn : Steve Arnold

**Date Rec. :** 15 January 2013  
**LR Report:** CA17789-JAN13

Box 20157, 131 St. Paul St.  
Belleville, ON  
K8N 5V1,

**Copy:** #1

Phone: 613-962-5454  
Fax:pdf-ID Plant

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	15-Jan-13	15-Jan-13	15-Jan-13
2: Analysis Start Time		---	---	14:31	14:31	11:55
3: Analysis Approval Date		--	--	16-Jan-13	16-Jan-13	17-Jan-13
4: Analysis Approval Time		--	--	15:35	15:35	11:49
5: MAC		--	--	0	0	---
6: 6712 NR/DW QMS Daycare	14-Jan-13 11:37	8.0	1.24	0	0	0
7: 1F432 NR/DW QMS Fountain Water: Front Entrance	14-Jan-13 11:45	8.0	1.06	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.



Carrie Greenlaw  
Project Specialist  
Environmental Services, Analytical