



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - K0L 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Works #:** 1156  
**Project :** PO#017018

30-January-2014

**OCWA-Trent Valley (Quinte Mohawk School)**

Attn : James Taylor

**Date Rec. :** 29 January 2014  
**LR Report:** CA18011-JAN14

Box 20157, 131 St. Paul St.  
Belleville, ON  
K8N 5V1,

**Copy:** #1

Phone: 613-962-5454  
Fax:pdf-ID Plant

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temp Upon Receipt °C	ResCl Free mg/L	Total Coliform cfu/100mL	E.Coli cfu/100mL
1: Analysis Start Date		---	---	29-Jan-14	29-Jan-14
2: Analysis Start Time		---	---	12:55	12:55
3: Analysis Approval Date		--	--	30-Jan-14	30-Jan-14
4: Analysis Approval Time		--	--	14:04	14:04
5: MAC		--	--	0	0
6: 26F9D RW RW-QMS: Raw Water 26F9D RW	28-Jan-14 08:58	4.0	---	0	0
7: 6712 NR DW DW1-QMS Daycare 6712 NR/DW	28-Jan-14 09:11	4.0	1.68	0	0
8: 1EC6A NR DW DW2-QMS Staff Room Tap 1EC6A NR/DW	28-Jan-14 09:19	4.0	1.52	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.  
NR - Not reportable under applicable Provincial drinking water regulations as per client.

Kimberley Didsbury  
Project Specialist  
Environmental Services, Analytical