**SGS Canada Inc.**
P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2HO
Phone: 705-652-2000 FAX: 705-652-6365

**Not Reportable as per Chain of Custody**
**Works #:** 1156

**Project :** PO#017018

18-September-2014

**OCWA-Trent Valley (Quinte Mohawk School)**
Attn : James Taylor

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Phone: 613-962-5454
Fax:pdf-ID Plant

**Date Rec. :** 16 September 2014
**LR Report:** **CA18108-SEP14**

**Copy:** #1

# CERTIFICATE OF ANALYSIS

## Final Report

| Sample ID | Sample Date & Time | Temperature Upon Receipt °C | Total Chlorine mg/L | Free Chlorine mg/L | Total Coliform cfu/100mL | E. Coli cfu/100mL | Heterotrophic Plate Count (HPC) cfu/1mL |
|---|---|---|---|---|---|---|---|
| 1: Analysis Start Date | | --- | --- | --- | 16-Sep-14 | 16-Sep-14 | 16-Sep-14 |
| 2: Analysis Start Time | | --- | --- | --- | 14:15 | 14:15 | 13:50 |
| 3: Analysis Approval Date | | -- | --- | -- | 17-Sep-14 | 17-Sep-14 | 18-Sep-14 |
| 4: Analysis Approval Time | | -- | --- | -- | 15:52 | 15:52 | 11:17 |
| 5: MAC | | -- | --- | -- | 0 | 0 | --- |
| 6: 26F9D RW RW QMS: Raw Water 26F9D RW | 15-Sep-14 08:25 | 16.0 | --- | --- | 0 | 0 | 6 |
| 7: 6712 NR DW DW1 QMS Daycare 6712 NR/DW | 15-Sep-14 08:15 | 16.0 | 1.63 | 1.45 | 0 | 0 | 1 |
| 8: 6711 NR DW DW3 Kitchen Tap 1156 NR/DW | 15-Sep-14 08:05 | 16.0 | 1.27 | 0.96 | 0 | 0 | 2 |

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.

*Carrie Greenlaw*
*Project Specialist*
*Environmental Services, Analytical*

OnLine LIMS

0000246271



Data reported represents the sample submitted to SGS. Reproduction of this analytical report in full or in part is prohibited without prior written approval. Please refer to SGS General Conditions of Services located at http://www.sgs.com/terms_and_conditions_service.htm. (Printed copies are available upon request.)
Test method information available upon request. “Temperature Upon Receipt” is representative of the whole shipment and may not reflect the temperature of individual samples.

**SGS Canada Inc.**
P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - KOL 2HO
Phone: 705-652-2000 FAX: 705-652-6365

**Not Reportable as per Chain of Custody**
**Works #:** 1156
**Project :** PO#017018
**LR Report :** **CA18108-SEP14**

# Method Descriptions

| | Parameter | Unit | Low Limit | Description | SGS Method Code |
|---|---|---|---|---|---|
| 1 | E. Coli | cfu/100mL | 0 | E.Coli by membrane filtration on DC media | ME-CA-[ENV]MIC-LAK-AN-001 |
| 2 | Heterotrophic Plate Count (HPC) | cfu/1mL | 0 | Heterotrophic Plate Count by membrane filtration | ME-CA-[ENV]MIC-LAK-AN-005 |
| 3 | Total Coliform | cfu/100mL | 0 | Total Coliform by membrane filtration using DC media | ME-CA-[ENV]MIC-LAK-AN-001 |

OnLine LIMS

0000246271



Data reported represents the sample submitted to SGS. Reproduction of this analytical report in full or in part is prohibited without prior written approval. Please refer to SGS General Conditions of Services located at http://www.sgs.com/terms_and_conditions_service.htm. (Printed copies are available upon request.)
Test method information available upon request. “Temperature Upon Receipt” is representative of the whole shipment and may not reflect the temperature of individual samples.