



**SGS Canada Inc.**

P.O. Box 4300 - 185 Concession St.  
Lakefield - Ontario - KOL 2H0  
Phone: 705-652-2000 FAX: 705-652-6365

**Project :** PO#017018

November-12-12

**OCWA-Trent Valley (Quinte Mohawk School)**

Attn : Steve Arnold

**Date Rec. :** 06 November 2012  
**LR Report:** CA16127-NOV12

Box 20157, 131 St. Paul St.  
Belleville, ON  
K8N 5V1,

**Copy:** #1

Phone: 613-962-5454  
Fax:pdf-ID Plant

# CERTIFICATE OF ANALYSIS

## Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	06-Nov-12	06-Nov-12	06-Nov-12
2: Analysis Start Time		---	---	13:05	13:05	12:35
3: Analysis Approval Date		--	--	08-Nov-12	08-Nov-12	09-Nov-12
4: Analysis Approval Time		--	--	08:37	08:37	16:00
5: MAC		--	--	0	0	---
6: 26F9D RW QMS: Raw Water Tap	05-Nov-12 09:55	5.0	---	0	0	36
7: 1ec6c NR/DW QMS Staff Room Tap	05-Nov-12 10:25	5.0	1.33	0	0	0
8: 6712 NR/DW QMS Daycare	05-Nov-12 10:18	5.0	1.36	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.



*Carrie Greenlaw*  
Carrie Greenlaw  
Project Specialist  
Environmental Services, Analytical