



SGS Canada Inc.

P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Project : PO#017018

October-25-12

OCWA-Trent Valley (Quinte Mohawk School)

Attn : Steve Arnold

Date Rec. : 23 October 2012

LR Report: CA18053-OCT12

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	23-Oct-12	23-Oct-12	23-Oct-12
2: Analysis Start Time		---	---	11:40	11:40	11:05
3: Analysis Approval Date		--	--	24-Oct-12	24-Oct-12	25-Oct-12
4: Analysis Approval Time		--	--	17:13	17:13	10:41
5: MAC		--	--	0	0	---
6: 6712 NR/DW QMS Daycare	22-Oct-12 10:41	14.0	0.97	0	0	0
7: 1ec6a NR/DW QMS Staff Room Tap	22-Oct-12 10:51	14.0	1.08	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.

Carrie Greenlaw
Project Specialist
Environmental Services, Analytical