



SGS Canada Inc.
P.O. Box 4300 - 185 Concession St.
Lakefield - Ontario - K0L 2H0
Phone: 705-652-2000 FAX: 705-652-6365

Project : PO#017018

January-02-13

OCWA-Trent Valley (Quinte Mohawk School)

Attn : Steve Arnold

Date Rec. : 27 December 2012
LR Report: CA14637-DEC12

Box 20157, 131 St. Paul St.
Belleville, ON
K8N 5V1,

Copy: #1

Phone: 613-962-5454
Fax:pdf-ID Plant

CERTIFICATE OF ANALYSIS

Final Report

Sample ID	Sample Date & Time	Temperature Upon Receipt °C	Free Chlorine mg/L	Total Coliform cfu/100mL	E. Coli cfu/100mL	Heterotrophic Plate Count (HPC) cfu/1mL
1: Analysis Start Date		---	---	27-Dec-12	27-Dec-12	27-Dec-12
2: Analysis Start Time		---	---	17:15	17:15	16:50
3: Analysis Approval Date		--	--	28-Dec-12	28-Dec-12	29-Dec-12
4: Analysis Approval Time		--	--	16:26	16:26	14:14
5: MAC		--	--	0	0	---
6: NR/DW Fountain Outside Daycare	27-Dec-12 07:58	6.0	0.51	0	0	0
7: 1ec6a NR/DW QMS Staff Lunch Room Tap	27-Dec-12 08:05	6.0	0.93	0	0	0

Total and/or Free Residual Chlorine was not analyzed by SGS Environmental Services.



Carrie Greenlaw
Project Specialist
Environmental Services, Analytical